



### Ambient Conditions

DB Temperature	20.9 °C
WB Temperature	10.9 °C
Humidity	27 %RH
Enthalpy	31.5 kJ/kg
Dewpoint	1.0 °C

  

**CHILLER PLANT ENABLE**

**OUTSIDE AIR LOCKOUT**

**AHU PLANT IN ECONOMY MODE**

**CHILLER SEQ**

- Chiller Plant Call
- Chiller Stage 1
- Chiller Stage 2
- Chiller Stage 3
- Chiller Stage 4
- Chiller Stage 5
- Chiller Stage 6

ChillerStep Up Pending   
 ChillerStep Down Pending

**CHILLER PLANT**

Total Cooling Demand	100 %
N Chilled Water Max Demand	100 %
S Chilled Water Max Demand	11 %
Chiller Water Field Demand	13 %

**CHILLER ENERGY**

System Cooling Capacity	5547.0 kW
Cooling Capacity Enabled is	1550.0 kW
CH 1 Kwr	944.4 kW
CH 2 Kwr	0.0 kW
CH 3 Kwr	0.0 kW
CH 4 Kwr	0.0 kW
Total kW	944.4 kW